

INDEX: ☐ YES ☐ NO

CLASSIFIED MESSAGE

TOTAL COPIES

CLASSIFY TO FILE NO.

X-REF TO FILE NO.

FILE RID ☐ RET. TO BRANCH ☐DESTROY ☐ SIG. ☐**SECRET**GROUP 1  
EXCLUDED FROM AUTOMATIC  
DOWNGRADING AND  
DECLASSIFICATION

REPRODUCTION PROHIBITED

PERSON/UNIT NOTIFIED

FROM

DISSEM By 8

ACTION

ADVANCE COPY

☐ RID COPY☐ ISSUED☐ DELETED

INFO

FILE, VR, FE

UNIT

TIME

BY

25X1A

25X1A

SECRET 130757Z CITE

LOGISTICS INFO DIRECTOR

25X1A

REF A

B LOGISTICS 5649

(34935)✓

1. REF B INDICATES WE FAILED MAKE OUR POINTS CLEAR OR WERE MISUNDERSTOOD.

2. OUR PARA 2 INDICATED WE HAVE PARTS ON HAND TO RESTORE DAMAGED GENERATOR TO ORIGINAL CONDITION,, NOT FOR UPRATING REBUILD. THE QUERY OUR PARA 3 WAS, IS IT POSSIBLE TO REBUILD THIS TYPE GENERATOR TO PRODUCE A HIGHER KW.

3. THERE IS NO CONNECTION REGULATOR FAILURE AND DAMAGED GENERATOR EXCEPT BOTH OCCURRED IN SAME AFTERNOON AND WEATHER WAS PRIME CAUSE FOR BOTH. TEST ON GENERATORS INDICATE INSULATION DETERIORATION

25X1A

COLLECTION CAUSED INSULATION TO FAIL AND ARC OCCURRED. WE FEEL OTHER GENERATORS MAY HAVE SAME FAILURE IF NOT CONVERTED SOONEST.

4. NOT SURE WE UNDERSTAND PARA 1 REF B AS REGULATORS ARE

AT INPUT POINT WHERE POWER ENTERS OUR SYSTEM. WE FEEL 2 SINGLE PHASE REGULATORS CAPABLE HANDLING POWER SURGES AND

FLUCTUATION OF POWER INTO OUR SYSTEM EXCEPT WE NOW READING

~~SECRET~~

25X1A

PAGE 2

NAME PLACE CAPACITY AND MUST HAVE REGULATORS WHICH CAN HANDLE NECESSARY LOAD.

25X1A

5. LOGISTICS ELECTRICAL ENG ALWAYS WELCOME BUT DISTRIBUTION NOT OUR PROBLEM. SYSTEM AS SEEN BY [REDACTED] LAST DEC NOT CHANGED.

6. HAVE \$1000,000 PROGRAMED FOR FY67 FOR POWER HOUSE AND ONE ADDITIONAL 500 KW GENERATOR.

7. AS OF THIS DATE FEEL WE MUST EXPEDITE REPAIRS PRESENT REGULATOR. WE HAVE FUNDS AVAILABLE HOPE HQS CAN ARRANGE PROCUREMENT AUTHORITY. WOULD HOPE FOR SHIPMENT FROM [REDACTED]

25X1A

8. ITEM NEEDED IS REGULATOR, VOLTAGE, ALLIS CHALMERS 5/8 PERCENT STEP JFR, SINGLE PHASE, 60 CYCLE, CLASS OA, 144 KVA, 14,400 VOLT, 100 AMP, SER NBR 3-2140-00210-12.

9. SER NBR ON OUR GENERATORS ARE [REDACTED]

25X1A

S E C R E T

BT

~~SECRET~~

*connect you amp to + 7 1/2 on board  
and operate at*

*KVA*

*10-14.4-288.0*

RECEIVED  
CONSTRUCTION  
JUN 13 3 02 PM '66